


All temperature sensors : lastday (5 minute samples)



outdoor	Min: 5.40	Max: 12.00	Average: 7.72	Current: 8.70 degrees Celsius
forward	Min: 27.10	Max: 46.80	Average: 32.96	Current: 32.10 degrees Celsius
return	Min: 26.70	Max: 44.30	Average: 31.34	Current: 30.30 degrees Celsius
Heatcompensate_setp	Min: 27.80	Max: 31.76	Average: 30.37	Current: 29.78 degrees Celsius
powerconsumption	Min: 0.04	Max: 3.06	Average: 0.76	Current: 0.56 kW
outputpower	Min: -2.00	Max: 6.63	Average: 2.71	Current: 3.06 kW
efficiency	Min: -2.12	Max: 7.04	Average: 3.88	Current: 5.47
flow	Min: 3.60	Max: 15.24	Average: 13.41	Current: 14.64
hotwater level 1	Min: 31.50	Max: 46.20	Average: 39.44	Current: 40.70 degrees Celsius
coil temp	Min: 1.40	Max: 22.70	Average: 9.42	Current: 6.20 degrees Celsius
exhaust gas	Min: 20.90	Max: 95.60	Average: 61.04	Current: 62.60 degrees Celsius
compressor_frequency	Min: 0.00	Max: 80.00	Average: 30.29	Current: 30.00 Hz
hotwater level 2	Min: 31.94	Max: 85.00	Average: 49.22	Current: 48.69 degrees Celsius