

outdoor :	Min: 0.15	Max: 12.00	Average: 5.52	Current: 8.70	degrees Celsius
forward :	Min: 27.35	Max: 46.55	Average: 33.88	Current: 32.00	degrees Celsius
return :	Min: 26.80	Max: 44.20	Average: 32.18	Current: 30.25	degrees Celsius
Heatcompensate_setp :	Min: 27.80	Max: 34.91	Average: 31.69	Current: 29.78	degrees Celsius
powerconsumption :	Min: -975.29	Max: 976.48	Average: 0.84	Current: 0.56	kW
outputpower :	Min: -0.75	Max: 6.18	Average: 2.91	Current: 2.98	kW
efficiency :	Min: -3.72	Max: 6.46	Average: 3.83	Current: 5.32	
flow :	Min: 3.66	Max: 22.68	Average: 14.21	Current: 14.64	
hotwater level 1 :	Min: 29.80	Max: 46.10	Average: 39.58	Current: 40.85	degrees Celsius
coil temp :	Min: -8.30	Max: 32.95	Average: 7.29	Current: 8.25	degrees Celsius
exhaust gas :	Min: 20.40	Max: 92.95	Average: 66.13	Current: 62.40	degrees Celsius
compressor_frequency :	Min: 0.00	Max: 80.00	Average: 35.01	Current: 30.00	Hz
hotwater level 2 :	Min: 21.78	Max: 71.50	Average: 50.85	Current: 49.50	degrees Celsius